

DEPARTMENT OF BUILDINGS
INC. VILLAGE OF EAST WILLISTON
2 PROSPECT STREET
EAST WILLISTON, NEW YORK 11596
516-746-0782

REQUIREMENTS FOR GENERATOR INSTALLATION

1. No generator shall be installed in a front yard of any property, or in any required side or rear yards.
2. Minimum setback from property line to generator shall be a minimum of five (5) feet.
3. Minimum setback from structure to generator shall be a minimum of five (5) feet.
4. Generator shall be placed upon a four (4) inch concrete pad and permanently affixed to said pad.
5. Generators installed within vehicle impact zone shall be protected by the following:
 - A. Steel bollards not less than four (4) inches in diameter and concrete filled.
 - B. Spaced not more than three (3) feet between posts.
 - C. Set not less than three (3) feet deep in concrete of not less than a fifteen (15) inch diameter.
 - D. Steel bollard set with the top of the post not less than three (3) feet above grade.
 - E. Steel bollard shall be located not less than three (3) feet from the generator.
6. Permits for Generators shall be applied for on a Village Generator Application form along with a survey denoting the unit and all required setbacks.
7. Applicant shall provide a copy of the manufacturer's specification manual.
8. Generator applications shall be submitted with a Gas Permit Application, survey denoting location of gas line to unit and size of piping.

**INCORPORATED VILLAGE OF EAST WILLISTON
DEPARTMENT OF BUILDINGS
2 PROSPECT STREET
EAST WILLISTON, NEW YORK 11596
TEL.#746-0782
FAX#746-3130**

GAS REQUIREMENTS FOR THE INSTALLATION OF A GENERATOR

1. LICENSED PLUMBER TO PROVIDE EXISTING AND NEW GAS METER SIZE TO ACCOMIDATE GENERATOR.
2. LICENSED PLUMBER MUST PROVIDE BTU INPUT FOR NEW GENERATOR.
3. LICENSED PLUMBER MUST PROVIDE EXISTING BTU LOAD ON BUILDING/ STRUCTURE.
4. LICENSED PLUMBER MUST PROVIDE OVERALL GAS PIPE SIZES AND LENGH FROM GAS METER TO PROPOSED GENERATOR.
5. LICENSED PLUMBER MUST CONFIRM OR HAVE INSTALLED CARBON MONOXIDE ALARM AND SMOKE DETECTORS AS PER NEW YORK STATE BUILDING CODE.
6. LICENSED PLUMBER TO SLEEVE ALL PENETRATIONS, INSTALL TRACER WIRE AND SAFETY TAPE IN TRENCH TO CODE AND HAVE ALL PIPING TRENCH INSPECTED PRIOR TO BACK FILLING.

THE BUILDING DEPARTMENT WILL NOT ALLOW FOR THE GAS TO BE TURNED ON UNTIL ALL LIFE SAFETY INSPECTIONS HAVE BEEN COMPLETED, NO EXCEPTIONS!

